

CUMMINS ENGINE COMPANY, INC

Columbus, Indiana 47201

ENGINE PERFORMANCE CURVE

Basic Engine Model: LTA10-G3

Curve Number: FR-2240

Page No.

Engine Critical Parts List:

CPL: 1443

Date: **29Sep98**

Displacement : **10.0** litre (**610** in³)


Bore : **125** mm (**4.92** in.) Stroke : **136** mm (**5.35** in.)

No. of Cylinders: 6 Aspiration: Turbocharged and Aftercooled

	Engine Speed	Standby Power		ver Prime Power		Continuous Power	
	RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
Ī	1500	246	330	224	300	168	225
	1800						

Engine Performance Data @ 1500 RPM

OUTI	PUT PO	WER	FUEL CONSUMPTION					
%	kWm	ВНР	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour		
STAN	STANDBY POWER							
100	246	330	0.192	0.316	55.6	14.7		
PRIME	IE POWER							
100	224	300	0.194	0.320	51.1	13.5		
75	168	225	0.197	0.325	39.0	10.3		
50	112	150	0.204	0.336	26.9	7.1		
25	56	75	0.229	0.379	15.1	4.0		
CONTINUOUS POWER								
100	168	225	N.A.	N.A.	N.A.	N.A.		



Engine Performance Data @ 1800 RPM

Not Available at 1800 RPM

Not Available at 1800 RPM

CONVERSIONS:

(Litres = U.S. Gal x 3.785)

(Engine kWm = BHP x 0.746)

 $(U.S. Gal = Litres \times 0.2642)$

(Engine BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

TECHNICAL DATA DEPT.

CERTIFIED WITHIN 5%

CHIEF ENGINEER

POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

Operation At Elevated Temperature And Altitude:

The engine may be operated at:

1500 RPM up to 5,000 ft (1525 m) and 104° F (40° C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

Cummins Engine Company, Inc.

Engine Data Sheet

DATA SHEET: DS-4773-B
DATE: 29Sep98
PERFORMANCE CURVE: FR-2240 ENGINE MODEL: LTA10-G3 **CONFIGURATION NUMBER:** D343123GX02

CPL NUMBER

• Engine Critical Parts List : 1443

INSTALLATION DIAGRAM

• Fan to Flywheel : 3626318

• Heat Exchanger Cooled :

GENERAL ENGINE DATA	
Type	
Aspiration	3
Bore x Stroke	, , ,
Displacement— in ³ (li Compression Ratio—	, , ,
Dry Weight	
Fan to Flywheel Engine	(kg) 1995 (906)
Heat Exchanger Cooled Engine	(),
Wet Weight	(kg) IN. A.
Fan to Flywheel Engine — Ib (· •,
Heat Exchanger Cooled Engine — Ib ((kg) N. A.
Moment of Inertia of Rotating Components	
with FW 2102 Flywheel — lb _m • ft ² (kg • line)	m^2) 61.5 (2.59)
• with FW —— Flywheel — lb _m • ft ² (kg • l	
Center of Gravity from Rear Face of Flywheel Housing (FH 2147) — in (r	nm) 25.4 (645)
Center of Gravity above Crankshaft Centerline	nm) 7.5 (190)
Maximum Static Loading at Rear Main Bearing — Ib ((kg) 2000 (908)
ENGINE MOUNTING	
Maximum Bending Moment at Rear Face of Block — lb • ft (N •	m) 1000 (1356)
EXHAUST SYSTEM	
Maximum Back Pressure — in Hg (mm	Hg) 3 (76)
Waxiiiiaiii Baaki 1055alo	(70)
AIR INDUCTION SYSTEM	
Maximum Intake Air Restriction	
• with Dirty Filter Element — in H ₂ O (mm H ₂	₂ O) 25 (635)
• with Normal Duty Air Cleaner and Clean Filter Element — in H ₂ O (mm H	₂ O) 10 (254)
• with Heavy Duty Air Cleaner and Clean Filter Element — in H ₂ O (mm H ₂	₂ O) 15 (381)
COOLING SYSTEM	
Coolant Capacity — Engine Only— US gal (li	iter) 3.38 (12.8)
— with Heat Exchanger — US gal (li	iter) N.A.
Maximum Coolant Friction Head External to Engine — 1800 rpm — psi (k	
— 1500 rpm — psi (k	Pa) 6 (41)
Maximum Static Head of Coolant Above Engine Crank Centerline — ft	
Standard Thermostat (Modulating) Range	` '
Minimum Pressure Cap — psi (k	
Maximum Top Tank Temperature for Standby Power °F (
Minimum Raw Water Flow @ 90°F to Heat Exchanger — US gpm (liter / n	` ,
Maximum Raw Water Inlet Pressure at Heat Exchanger — psi (k	Pa) N.A.
LUBRICATION SYSTEM	
Oil Pressure @ Idle Speed	Pa) 15 (103)
·	,
@ Governed Speed	
Maximum Oil Temperature	()
Oil Capacity with OP 2056 Oil Pan: High - Low	,
Total System Capacity (with Combo Filter)	
Angularity of OP 2056 Oil Pan — Front Down	
— Front Up	
— Side to Side	42°

FUEL SYSTEM

Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter — in Hg (mm Hg)	4.0	(102)
— with Dirty Fuel Filter in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump	57	(216)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above	600	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	640	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	900	
COLD START CAPABILITY		
Minimum Ambient Temperature for Aided (with Coolant Heater) Cold Start within 10 seconds	50	(10)
Minimum Ambient Temperature for Unaided Cold Start	30	(-1)

PERFORMANCE DATA

All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046, Part 1, Standard Reference Conditions of:

Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature : 25°C (77°F)
Altitude : 110 m (361 ft) Relative Humidity : 30%

Engine Data with Dry Type Exhaust Manifold Intake Air Flow — cfm (liter / s) Exhaust Gas Temperature — °F (°C) Exhaust Gas Flow — cfm (liter / s) Air to Fuel Ratio — air : fuel Radiated Heat to Ambient — BTU / min (kW_m) Heat Rejection to Coolant — BTU / min (kW_m)

Heat Rejection to Exhaust BTU / min (kW_m)

	NDBY_		PRIME POWER			
60 hz 50 hz		60 hz	50 hz			
Not Available at		500 (246) (1972) (6.8) (19) (4.7) (4.2)	Not Available at 1800 RPM		500 5 - 750 (224) (1793) (6.8) (19) (4.7) (4.2)	
1800 RPM (60hz)	535 970 1475 22. 1910 7260 8660	(253) (521) (696) 6:1 (34) (128) (152)	(60hz)	505 950 1370 23. 1755 6600 8150	(238) (510) (647) 2:1 (31) (116) (143)	

N.A. - Data is Not AvailableN/A - Not Applicable to this EngineTBD - To Be Determined

ENGINE MODEL: LTA10-G3
DATA SHEET: DS-4773-B

DATE: 29Sep98 **CURVE NO**.: FR-2240